



Pearl Street Pump Station Conceptual Design Update

Brad Weeks, Director of Water Resource Protection

Megan McDevitt, PE, Woodard & Curran

July 16, 2024

Pearl Street Pump Station



- ✓ Originally constructed in 1972
- ✓ Receives flow from western portion of the City's collection system
- ✓ Pumps flow to the WWTP via a 24-inch force main located beneath the Fore River
- ✓ Maximum pumping rate of 14.8 MGD




Pearl Street Pump Station - Observed Deficiencies



- ✓ Pumps beyond useful life
- ✓ Electrical systems beyond useful life
- ✓ Mechanical systems beyond repair
- ✓ Undersized wet wells that can't be isolated
 - ✓ Recently unable to shutdown wet well to repair failed pipe
- ✓ Grit system undersized for larger storm events
- ✓ Station located within floodplain
- ✓ Original generator backing up the standby generator due to age and questionable reliability
- ✓ Safety hazards throughout
 - ✓ Inadequate fall protection at floor openings
 - ✓ Insufficient lighting

South Portland CSO Progress - DEP Permit Approval




- ✓ MaineDEP approved the CSO Facility Plan Update on July 21, 2022. Approval includes:
 - ✓ Implementation of the 4 recommended significant infrastructure improvement projects over 10 years.
 - ✓ Continued targeted infiltration renewal annually
 - ✓ Approval of an Emergency Overflow on both the east and west collection systems at the appropriate future time.
- ✓ MaineDEP commended the City for developing a plan that abated CSOs while simultaneously upgrading sewer infrastructure at the end of its service life





CSO Progress – DEP Approved Recommendations



Alternative 7

Raise CSO #006 Weir

- 6" to reduce overflows at CSO #006. (DEP Primary Directive)

Alternative 9

Increase Conveyance Capacity from CSO #006 to Pearl St Pump Station

- Replacing approximately 2,900 linear feet of piping along Greenbelt Walkway; North Kelsey Street; Pearl Street
- Piping sized to eliminate overflow at CSO #005 and CSO #006 during the 5-year design storm. (DEP Primary Directive)

Alternative 10

Increase Pearl Street Pump Station Capacity

- Upgrading pump station from a peak capacity of 16 MGD to 18 MGD

Alternative 15

Targeted Infiltration Study & Renewal Program

- Implementation of an annual sewer lining program to reduce infiltration into the collection system



Pearl Street Upgrades – Project Objectives


1. **Increase pump station capacity to 18 MGD** Peak Wet Weather Flow in accordance with the recommendation of the City's permitted 2022 CSO Facilities Plan update;
2. **Improve the pump station's headworks performance** for screening and grit removal up to and including the Peak Wet Weather Flow;
3. Replace the force main with **multiple new force mains to increase capacity, redundancy, and ability to handle wide range of flows;** and
4. Incorporate **climate change considerations**, such as sea level rise, in accordance with the City's implemented climate adaptation requirements and measures.

Pearl Street Upgrades – FM Alternatives Identified



✓ Two force main alternative alignments were identified:

- ✓ Across Fore River (2,500 LF)
- ✓ Along Greenbelt Walkway (5,100 LF)





Pearl Street Upgrades – PS Alternatives Identified

- ✓ 10 pump station alternatives were identified consisting of:
 - ✓ Send gravity flow directly to the WWTP
 - ✓ Rehabilitate existing pump station
 - ✓ Build at an alternative site

#	Alternative
1. Gravity to WWTP	
1A.	To Existing Main Pump Station
1B.	To New Combined Headworks & Main Pump Station
1C.	New Headworks at 6 Pearl Street to New Main Pump Station
2. Pump Station at Existing Site Only	
2A.	Rehab Existing – No Reconfiguration
2B.	Rehab Existing – Reconfigure
2C.	Demolish and Rebuild
3. Pump Station at Alternate Site (6 Pearl Street)	
3A.	New Pump Station/Headworks
3B.	New Pump Station & New Headworks at Existing Site
3C.	New Pump Station with Screening & New Grit Removal at WWTP
3D.	New Pump Station, New Screening at Existing Site, & New Grit Removal at WWTP



Pearl Street Upgrades – Evaluation of PS Alternatives

✓ Utilized a green, yellow, red color-coding screening system to depict evaluation criteria including:

- ✓ Technical Feasibility
- ✓ Project Objectives
- ✓ Regulatory Feasibility
- ✓ Constructability
 - ✓ (Geotechnical & Bypass Pumping)
- ✓ Long-Term Operations & Maintenance
- ✓ Cost Considerations
 - ✓ (Construction + O&M)


#	Alternative	Technical Feasibility	Project Objectives	Regulatory Feasibility	Constructability		Long-Term Operations & Maintenance	Cost Considerations (Construction + O&M)	Feasible
					Geotech	Bypass Pumping			
1. Gravity to WWTP									
1A.	To Existing Main Pump Station at WWTP	Y	Y	Y	R	R	R	R	X
1B.	To New Combined Headworks & Main Pump Station at WWTP	Y	Y	Y	Y	R	R	R	X
1C.	New Headworks at 6 Pearl St. to New Pump Station at WWTP	Y	G	Y	Y	G	R	R	X
2. Pump Station at Existing Site									
2A.	Rehab Existing – No Reconfiguration	Y	R	Y	G	R	R	Y	X
2B.	Rehab Existing – Reconfigure	G	Y	Y	G	R	Y	Y	✓
2C.	Demolish and Rebuild	Y	G	R	Y	R	G	R	X
3. Pump Station at Alternate Site (6 Pearl St.)									
3A.	New Pump Station /Headworks	G	G	Y	Y	G	G	Y	✓
3B.	New Pump Station & New Headworks at Existing Site	G	G	Y	Y	G	G	Y	✓
3C.	New Pump Station with Screening & New Grit Removal at WWTP	G	Y	Y	Y	Y	Y	R	X
3D.	New Pump Station, New Screening at Existing Site, & New Grit Removal at WWTP	G	Y	Y	Y	Y	Y	R	X



Pearl Street Upgrades – Recommended FM Plan

► Fore River Alignment Alternative - Two 20" Diameter Force Mains

- Fore River alignment has lower estimated project cost due to its shorter proposed alignment.
 - Greenbelt Walkway Alignment additional length requires larger pumps, increasing the size and O&M requirements of the pump station.
- Two force mains provide redundancy for most of the anticipated daily flows and increased capacity for larger wet weather events.




Additional Recommendation: Investigate potential reuse of the existing force main as an emergency force main for the new pump station.



Pearl Street Upgrades – Recommended PS Plan

► Alternative 3B - New Pump Station at 6 Pearl Street and a New Headworks at the Existing Site

- Achieves all project objectives without compromising long-term operations and maintenance
- Reutilizes existing pump station to minimize construction of new below grade structures
- Proposed Headworks located at the existing pump station site reduces nuisance odors at Greenbelt Walkway and residential houses
- Lower estimated project cost compared to other feasible alternatives




Pearl Street Upgrades – Opinion of Probable Project Cost



Item	Description	Opinion of Probable Cost
Construction Costs		
1	Force Main (Fore River Alignment)	\$7,840,000
2	Pump Station Upgrades (Alternative 3B)	\$23,450,000
Construction Subtotal (2026)		\$31,290,000
Project Costs		
	Land Acquisition (6 Pearl Street)	\$1,000,000
	Engineering Fee - Permitting, Design & Construction Administration Services (15%)	\$4,700,000
	Other Administrative and Permitting Fees (1%)	\$320,000
Indirect Project Costs Subtotal		\$6,020,000
Total Indirect Project + Construction Cost Range (AACE Level 4)		
Total Indirect Project + Construction Costs		\$37,310,000
	Low End (-20%)	\$29,850,000
	High End (+30%)	\$48,510,000

Pearl Street Upgrades – Proposed Project Schedule



Project Phase	Projected Schedule
Force Main Permitting & Preliminary Site Investigations	August 2024 – December 2024
Final Design & Permitting	January 2025 – November 2025
Bid Phase	December 2025 – February 2026
Bond for Public Referendum	June 2026
Award Construction Contract ¹	July 2026
Notice to Proceed with Construction	August 2026
Substantial Completion	June 2028
Final Completion	September 2028

¹ Assumes Bond Passage with Bond for Public Referendum

Thank You